

**FIRE PREVENTION CODE (EXCERPT)**  
**Act 207 of 1941**

**29.3d Installation of manual fire alarm box required in schools; exception.**

Sec. 3d.

A school that has a vestibule is not required to install a manual fire alarm box within the vestibule if a manual fire alarm box is located within 5 feet of the interior door of the vestibule.

**History:** Add. 2019, Act 19, Eff. Sept. 5, 2019

**Compiler's Notes:** Former MCL 29.3d, which pertained to rules relating to moving picture theaters, was repealed by Act 189 of 2006, Imd. Eff. June 19, 2006.